



# CLARK COUNTY DEPARTMENT OF BUILDING

## Field Inspection Guideline



**SUBJECT:** Service Signage

**FIG-E-014**

**Effective Date:** January 5, 2007

**Revised:** April 04, 2014

**Approved By:** BAT

**Code Chapter:** 2011 NEC Sec/ 230.2 (E) & 230.70 (B) Amendments 230.70 (B)

**Page 1 of 1**

**Interpretation:** The NEC allows multiple services and requires permanent marking and a plaque to identify multiple service disconnects. Southern Nevada Amendments specify requirements for signs at each service disconnect.

**Field Application:** Service "disconnect" signs and multiple service plaques shall meet the following requirements:

- Each service disconnecting means and the exterior door providing access to the disconnecting means located in an approved electrical equipment room shall be permanently marked with a sign(s). Each sign shall be a minimum 1 square foot, colored yellow with 1 inch high, ¼ inch stroke raised or engraved letters and/or numbers indicating the address or unit it serves and be identified as the "Main Electrical Disconnect" and/or "Main Electrical Disconnect Inside".
- Emergency system disconnects shall be permanently marked with sign(s), identified as "Emergency Electrical Disconnect" and/or "Main Emergency Electrical Disconnect Inside".
- Where more than one service to a building or structure is permitted, a graphic display plaque shall be installed at each service location. The location of all services shall be shown and the area served by each noted.
- The Graphic Display Plaque shall be of metal or laminated plastic with engraved or raised lines minimum 1/16 inch depth and width with a minimum ½ inch height. The plaque shall show the outline of the building with the north direction displayed, and the location of all services serving the building. The plaque shall be secured to the service and denote the area served by that service.

**Exception:** One and two family dwelling units and their associated accessory structures.

### Revision History:

Reference #	Title	Effective Date	Revised	Reviewed
FIG-E-014	Permanent dPlaque for Services	January 5, 2007		May 23, 2013
FIG-E-014	Service Signage		April 04, 2014	